

STANDARDIZED MONITORING FRAMEWORK 2 (SMF 2)

Without Exceeding Detection Limits, Maximum Contaminant Levels, or Action Levels

System Name: **Goshen Water Department**

Entry Point: **01 - North 5th St.**

PWSID# **5220009**

<<<< NINE YEAR COMPLIANCE CYCLE >>>>										
REGULATED Contaminants	First Compliance Period			Second Compliance Period			Third Compliance Period			
	1993	1994	1995	1996	1997	1998	1999	2000	2001	
VOCs		Quarterly	Annual	Annual	Annual	Annual	Annual	Annual *	Annual	
SOCs **			Quarterly			Annual			Annual	
IOCs		Annual			Annual			Annual		
Asbestos			Annual							
PCBs & Dioxin										
Nitrate	Annual	Annual	Annual	Annual	Annual	Annual	Annual	Annual	Annual	
Cyanide, Nitrite, & Glyphosate										

* Regulated and Unregulated VOCs are required in 2000.

** Includes Pesticides

UNREGULATED Contaminants	Third Compliance Period		
	1999	2000	2001
VOCs		Annual	

Please contact the Drinking Water Branch at 317/308-3282
if you have any detections or exceed a maximum contaminant level.

Other Monitoring Requirements	1993	1994	1995	1996	1997	1998	1999	2000	2001
	Bacteriological	25 per month	25 per month	25 per month	25 per month	25 per month	25 per month	25 per month	25 per month
Lead & Copper		30 per year	30 per year	30 per year			30 per year		
Sodium	One sample every three years				Annual			Annual	
TTHMs	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant
Radionuclides						Annual			

STANDARDIZED MONITORING FRAMEWORK 2 (SMF 2)

Without Exceeding Detection Limits, Maximum Contaminant Levels, or Action Levels

System Name: Goshen Water Department

Entry Point: 02 - Kercher

PWSID# 5220009

<<<< NINE YEAR COMPLIANCE CYCLE >>>>									
REGULATED Contaminants	First Compliance Period			Second Compliance Period			Third Compliance Period		
	1993	1994	1995	1996	1997	1998	1999	2000	2001
VOCs		Quarterly	Annual	Annual	Annual	Annual	Annual	Annual *	
SOCs ***			Quarterly			Annual **			Annual
IOCs		Annual			Annual			Annual	
Asbestos			Annual						
PCBs & Dioxin									
Nitrate	Annual	Annual	Annual	Annual	Annual	Annual	Annual	Annual	Annual
Cyanide, Nitrite, & Glyphosate									

*** Includes Pesticides

* Regulated and Unregulated VOCs are required in 2000.

UNREGULATED Contaminants	Third Compliance Period		
	1999	2000	2001
VOCs		Annual	

** 2,4-D, Alachlor, Atrazine, and Simazine are required in the second and third quarter of 1998.

Please contact the Drinking Water Branch at 317/308-3282 if you have any detections or exceed a maximum contaminant level.

Other Monitoring Requirements	1993	1994	1995	1996	1997	1998	1999	2000	2001
	Bacteriological	25 per month	25 per month	25 per month	25 per month	25 per month	25 per month	25 per month	25 per month
Lead & Copper		30 per year	30 per year	30 per year			30 per year		
Sodium	One sample every three years				Annual			Annual	
TTHMs	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant	1 / qtr / plant
Radionuclides						Annual			